



# Certificate / Certificat Zertifikat / 合格証

PRE 21-09-063 C001

*exida* hereby confirms that the:

## Staset Pressure Indicating Switch Precision Sensors

The manufacturer  
may use the mark:



Has been assessed per the relevant requirements of:

**IEC 61508:2010 Part 1-2**

**ISO 13849-1: 2015**

and meets requirements providing a level of integrity to:

**Systematic Capability: SC 3 (SIL 3 Capable)**

**Random Capability: Type A Element**

**SIL 2 @ HFT=0; SIL 3 @ HFT = 1; Route 2<sub>H</sub>**

**PFH/PFD<sub>avg</sub> and Architecture Constraints  
must be verified for each application**

Revision 2.0 July 17, 2025  
Surveillance Audit Due  
July 1, 2028

### Certified Models:

Only the Model numbers listed in Section 3 of the Assessment Report are included.

### Safety Function:

The Staset Gen 3 Series Pressure Switch sets the switch output to the de-energized state when the measured pressure exceeds one of up to two switch points.

### Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.



Evaluating Assessor

Certifying Assessor

PRE 21-09-063 C001

**Systematic Capability: SC 3 (SIL 3 Capable)**

**Random Capability: Type A Element**

**SIL 2 @ HFT=0; SIL 3 @ HFT = 1; Route 2<sub>H</sub>**

**PFH/PFD<sub>avg</sub> and Architecture Constraints must be verified for each application**

Staset Pressure  
Indicating Switch

**Systematic Capability:**

The product has met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

**Random Capability:**

The SIL limit imposed by the Architectural Constraints must be met for each element. This element meets *exida* criteria for Route 2<sub>H</sub>.

**IEC 61508 Failure Rates in FIT\***

Application/Device/Configuration	$\lambda_{SD}$	$\lambda_{SU}^3$	$\lambda_{DD}$	$\lambda_{DU}$	#
Open High Iout	0	165	0	74	265
Open High Vout	0	164	0	74	239
Open Low Iout	0	144	0	100	261
Open Low Vout	0	142	0	100	235
Open In Window Iout	0	144	0	81	260
Open In Window Vout	0	143	0	81	236
Open Out of Window Iout	0	156	0	69	260
Open Out of Window Vout	0	155	0	69	235

\* FIT = 1 failure / 10<sup>9</sup> hours

**SIL Verification:**

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFH/PFD<sub>avg</sub> considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

**Assessment Report:** PRE 21-09-063 R002 V2R0

**Safety Manual:** Staset Gen 3 Series – Safety Manual (Rev. B or later)



80 N Main St  
Sellersville, PA 18960